eurofins | Eaton Analytical

LABORATORY REPORT

This report contains 11 pages.
(including the cover page)

If you have any questions concerning this report, please do not hesitate to call us at (800) 332-4345 or (574) 233-4777.

eurofins | Eaton Analytical

110 South Hill Street
South Bend, IN 46617
Tel: (574) 233-4777
Fax: (574) 233-8207
1 800 332 4345

Laboratory Report

Client: Village of Hoosick Falls

Attn: Jim Hurlburt
240 Main Street
Hoosick Falls, NY 12090

Copies to: None

Report: 333233
Priority: Standard Written
Status: Final
PWS ID: Not Supplied
Lab ELAP #: 11398

Sample Information

EEA ID #	Client ID	Method	Collected Date / Time	Collected By:	Received Date / Time
3179028	Hoosick River-Upstream	537	01/29/15 10:30	Client	01/30/15 09:00
3179029	Finished Water Plant	537	01/29/15 10:57	Client	01/30/15 09:00
3179030	Well #7	537	01/29/15 11:10	Client	01/30/15 09:00
3179031	Well #3	537	01/29/15 11:20	Client	01/30/15 09:00
3179032	G.A.C Finished	537	01/29/15 11:25	Client	01/30/15 09:00
3179033	Highway Garage	537	01/29/15 11:40	Client	01/30/15 09:00
3179034	Rt. 22 21953 True Value	537	01/29/15 11:55	Client	01/30/15 09:00
3179035	Sample 1-Raw Water	537	01/29/15 12:25	Client	01/30/15 09:00
3179036	Sample 2-Raw Water	537	01/29/15 12:25	Client	01/30/15 09:00
3179037	Sample 3-Raw Water	537	01/29/15 12:25	Client	01/30/15 09:00
3179038	Sample 4	537	01/30/15 00:00	EEA	01/30/15 09:00
3179039	Sample 5	537	01/30/15 00:00	EEA	01/30/15 09:00
3179040	Sample 6	537	01/30/15 00:00	EEA	01/30/15 09:00
3179041	Sample 7	537	01/30/15 00:00	EEA	01/30/15 09:00
3179042	Sample 8	537	01/30/15 00:00	EEA	01/30/15 09:00

Report Summary

Detailed quantitative results are presented on the following pages. The results presented relate only to the samples provided for analysis.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call Nathan Trowbridge at (574) 233-4777.

Authorized Signature | Title: C.S. Manager | Date: 02/11/2015

Client Name: Village of Hoosick Falls
Report #: 333233

Client Name: Village of Hoosick Falls Report #: 333233

Sampling Point: Hoosick River-Upstream PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/05/15 23:38	3179028
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/05/15 23:38	3179028
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/05/15 23:38	3179028
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/05/15 23:38	3179028
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/05/15 23:38	3179028
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/05/15 23:38	3179028

Sampling Point: Finished Water Plant PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 00:09	3179029
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	**10**	ng/L	02/02/15 07:30	02/06/15 00:09	3179029
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 00:09	3179029
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 00:09	3179029
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 00:09	3179029
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**530**	ng/L	02/02/15 07:30	02/06/15 09:35	3179029

Sampling Point: Well #7 PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 00:39	3179030
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	**10**	ng/L	02/02/15 07:30	02/06/15 00:39	3179030
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 00:39	3179030
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 00:39	3179030
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 00:39	3179030
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**520**	ng/L	02/02/15 07:30	02/06/15 10:06	3179030

Client Name: Village of Hoosick Falls Report #: 333233

Sampling Point: Well #3 PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 01:10	3179031
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 01:10	3179031
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 01:10	3179031
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 01:10	3179031
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 01:10	3179031
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**160**	ng/L	02/02/15 07:30	02/06/15 01:10	3179031

Sampling Point: G.A.C Finished PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 01:41	3179032
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	**10**	ng/L	02/02/15 07:30	02/06/15 01:41	3179032
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 01:41	3179032
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 01:41	3179032
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 01:41	3179032
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**470**	ng/L	02/02/15 07:30	02/06/15 10:36	3179032

Sampling Point: Highway Garage PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 02:12	3179033
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	**10**	ng/L	02/02/15 07:30	02/06/15 02:12	3179033
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 02:12	3179033
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 02:12	3179033
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 02:12	3179033
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**520**	ng/L	02/02/15 07:30	02/06/15 11:07	3179033

Client Name: Village of Hoosick Falls Report #: 333233

Sampling Point: Rt. 22 21953 True Value PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 03:45	3179034
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	**10**	ng/L	02/02/15 07:30	02/06/15 03:45	3179034
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 03:45	3179034
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 03:45	3179034
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 03:45	3179034
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**510**	ng/L	02/02/15 07:30	02/06/15 11:38	3179034

Sampling Point: Sample 1-Raw Water PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 04:16	3179035
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 04:16	3179035
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 04:16	3179035
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 04:16	3179035
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 04:16	3179035
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**330**	ng/L	02/02/15 07:30	02/06/15 12:09	3179035

Sampling Point: Sample 2-Raw Water PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 04:47	3179036
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 04:47	3179036
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 04:47	3179036
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 04:47	3179036
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 04:47	3179036
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**330**	ng/L	02/02/15 07:30	02/06/15 12:40	3179036

Client Name: Village of Hoosick Falls Report #: 333233

Sampling Point: Sample 3-Raw Water PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 05:18	3179037
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 05:18	3179037
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 05:18	3179037
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 05:18	3179037
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 05:18	3179037
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**330**	ng/L	02/02/15 07:30	02/06/15 13:11	3179037

Sampling Point: Sample 4 PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 05:49	3179038
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 05:49	3179038
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 05:49	3179038
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 05:49	3179038
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 05:49	3179038
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**260**	ng/L	02/02/15 07:30	02/06/15 05:49	3179038

Sampling Point: Sample 5 PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 06:19	3179039
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 06:19	3179039
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 06:19	3179039
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 06:19	3179039
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 06:19	3179039
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**260**	ng/L	02/02/15 07:30	02/06/15 06:19	3179039

Client Name: Village of Hoosick Falls Report #: 333233

Sampling Point: Sample 6 PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 06:50	3179040
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 06:50	3179040
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 06:50	3179040
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 06:50	3179040
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 06:50	3179040
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**260**	ng/L	02/02/15 07:30	02/06/15 06:50	3179040

Sampling Point: Sample 7 PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 07:21	3179041
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 07:21	3179041
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 07:21	3179041
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 07:21	3179041
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 07:21	3179041
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**260**	ng/L	02/02/15 07:30	02/06/15 07:21	3179041

Sampling Point: Sample 8 PWS ID: Not Supplied

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	90	< 90	ng/L	02/02/15 07:30	02/06/15 07:52	3179042
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	10	< 10	ng/L	02/02/15 07:30	02/06/15 07:52	3179042
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	30	< 30	ng/L	02/02/15 07:30	02/06/15 07:52	3179042
375-95-1	Perfluorononanoic acid (PFNA)	537	---	20	< 20	ng/L	02/02/15 07:30	02/06/15 07:52	3179042
1763-23-1	Perfluorooctane sulfonate (PFOS)	537	---	40	< 40	ng/L	02/02/15 07:30	02/06/15 07:52	3179042
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	20	**250**	ng/L	02/02/15 07:30	02/06/15 07:52	3179042

† EEA has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

Reg Limit Type:	MCL	SMCL	AL
Symbol:	*	^	!

Lab Definitions

Continuing Calibration Check Standard (CCC) / Continuing Calibration Verification (CCV) / Initial Calibration Verification Standard (ICV) / Initial Performance Check (IPC) - is a standard containing one or more of the target analytes that is prepared from the same standards used to calibrate the instrument. This standard is used to verify the calibration curve at the beginning of each analytical sequence, and may also be analyzed throughout and at the end of the sequence. The concentration of continuing standards may be varied, when prescribed by the reference method, so that the range of the calibration curve is verified on a regular basis.

Internal Standards (IS) - are pure compounds with properties similar to the analytes of interest, which are added to field samples or extracts, calibration standards, and quality control standards at a known concentration. They are used to measure the relative responses of the analytes of interest and surrogates in the sample, calibration standard or quality control standard.

Laboratory Duplicate (LD) - is a field sample aliquot taken from the same sample container in the laboratory and analyzed separately using identical procedures. Analysis of laboratory duplicates provides a measure of the precision of the laboratory procedures.

Laboratory Fortified Blank (LFB) / Laboratory Control Sample (LCS) - is an aliquot of reagent water to which known concentrations of the analytes of interest are added. The LFB is analyzed exactly the same as the field samples. LFBs are used to determine whether the method is in control.

Laboratory Method Blank (LMB) / Laboratory Reagent Blank (LRB) - is a sample of reagent water included in the sample batch analyzed in the same way as the associated field samples. The LMB is used to determine if method analytes or other background contamination have been introduced during the preparation or analytical procedure. The LMB is analyzed exactly the same as the field samples.

Laboratory Trip Blank (LTB) / Field Reagent Blank (FRB) - is a sample of laboratory reagent water placed in a sample container in the laboratory and treated as a field sample, including storage, preservation, and all analytical procedures. The FRB/LTB container follows the collection bottles to and from the collection site, but the FRB/LTB is not opened at any time during the trip. The FRB/LTB is primarily a travel blank used to verify that the samples were not contaminated during shipment.

Matrix Spike Duplicate Sample (MSD) / Laboratory Fortified Sample Matrix Duplicate (LFSMD) - is a sample aliquot taken from the same field sample source as the Matrix Spike Sample to which known quantities of the analytes of interest are added in the laboratory. The MSD is analyzed exactly the same as the field samples. Analysis of the MSD provides a measure of the precision of the laboratory procedures in a specific matrix.

Matrix Spike Sample (MS) / Laboratory Fortified Sample Matrix (LFSM) - is a sample aliquot taken from field sample source to which known quantities of the analytes of interest are added in the laboratory. The MS is analyzed exactly the same as the field samples. The purpose is to demonstrate recovery of the analytes from a sample matrix to determine if the specific matrix contributes bias to the analytical results.

Quality Control Standard (QCS) / Second Source Calibration Verification (SSCV) - is a solution containing known concentrations of the analytes of interest prepared from a source different from the source of the calibration standards. The solution is obtained from a second manufacturer or lot if the lot can be demonstrated by the manufacturer as prepared independently from other lots. The QCS sample is analyzed using the same procedures as field samples. The QCS is used as a check on the calibration standards used in the method on a routine basis.

Reporting Limit Check (RLC) / Initial Calibration Check Standard (ICCS) - is a procedural standard that is analyzed each day to evaluate instrument performance at or below the minimum reporting limit (MRL).

Surrogate Standard (SS) / Surrogate Analyte (SUR) - is a pure compound with properties similar to the analytes of interest, which is highly unlikely to be found in any field sample, that is added to the field samples, calibration standards, blanks and quality control standards before sample preparation. The SS is used to evaluate the efficiency of the sample preparation process.

eurofins | Eaton Analytical

110 S. Hill Street
South Bend, IN 46617
T: 1.800.332.4345
F: 1.574.233.8207

Order # 270321
Batch # 333283

www.eatonanalytical.com

Shaded area for EEA use only

CHAIN OF CUSTODY RECORD

Page 1 of 1

REPORT TO:	SAMPLER (Signature)	PWS ID #	STATE (sample origin)	PROJECT NAME	PO#
Vill			NY		

BILL TO: Village of Hoosick Falls, 24 Main St. Hoosick Falls NY 12090

COMPLIANCE MONITORING	Yes	No	POPULATION SERVED	SOURCE WATER
		X		GWUDI

LAB Number	COLLECTION DATE	COLLECTION TIME	AM	PM	SAMPLING SITE	TEST NAME	SAMPLE REMARKS	CHLORINATED YES	CHLORINATED NO	# OF CONTAINERS	MATRIX CODE	TURNAROUND TIME
1	1/29/15	10:30	X		Hoosick River-Upstream		A					
2 3179,028	1/29/15	10:30	X		Hoosick River Upstrem							
3	1/29/15	10:30	X		Hoosick River Upstream							
4	1/29/15	10:57	X		Finished Water Plant							
5 029	1/29/15	10:57	X		Finished Water Plant							
6	1/29/15	10:57	X		~~Well #~~ Finished Water Plant							
7	1/29/15	11:10	X		Well #7							
8 030	1/29/15	11:10	X		Well #7							
9	1/29/15	11:10	X		Well #7							
10	1/29/15	11:26	X		Well #3							
11 031	1/29/15	11:20	X		Well #3							
12	1/29/15	11:26	X		well #3							
13 032	1/29/15	11:25	X		G.A.C. - Finisle 0							
14	1/29/15	11:25	X		G+C Finished							

RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED BY:(Signature)	DATE	TIME
	1/29/15	1245 AM PM			AM PM
RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED BY:(Signature)	DATE	TIME
		AM PM			AM PM
RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED FOR LABORATORY BY:	DATE	TIME
		AM PM	KDuvs	1-30-15	0900 AM PM

LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT

LAB COMMENTS

NO FTB received - transfer water bottle was still full. ss 1-30-15 use as LTB per narrow T.

CONDITIONS UPON RECEIPT (check one): X Iced: Wet/Blue ___ Ambient 4 °C Upon Receipt___ N/A

MATRIX CODES:

DW-DRINKING WATER
RW-REAGENT WATER
GW-GROUND WATER
EW-EXPOSURE WATER
SW-SURFACE WATER
PW-POOL WATER
WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES

SW = Standard Written: (15 working days) 0%
RV* = Rush Verbal: (5 working days) 50%
RW* = Rush Written: (5 working days) 75%
IV* = Immediate Verbal: (3 working days) 100%
IW* = Immediate Written: (3 working days) 125%
SP* = Weekend, Holiday CALL
STAT* = Less than 48 hours CALL

* Please call, expedited service not available for all testing

Samples received unannounced with less than 48 hours holding time remaining may be subject to additional charges.

eurofins | Eaton Analytical

110 S. Hill Street
South Bend, IN 46617
T: 1.800.332.4345
F: 1.574.233.8207

Order # 270321
Batch # ______

www.eatonanalytical.com

CHAIN OF CUSTODY RECORD

Page ____ of ____

Shaded area for EEA use only

REPORT TO:

BILL TO: Hoosick Falls
24 Main St. Hoosick Falls

SAMPLER (Signature): [signature]

COMPLIANCE MONITORING: Yes ____ No X

PWS ID #	STATE (sample origin)	PROJECT NAME	PO#
	NY		
POPULATION SERVED	SOURCE WATER		
	GWUDI		

	LAB Number	COLLECTION DATE	TIME	AM	PM	SAMPLING SITE	TEST NAME	SAMPLE REMARKS	CHLORINATED YES	NO	# OF CONTAINERS	MATRIX CODE	TURNAROUND TIME
1	——— SS	1/29/15	11:35	X		GAC Finished		A					
2	3179033	1/29/15	11:40	X		Highway Garage							
3		1/29/15	11:40	X		Highway Garage							
4		1/29/15	11:40	X		Highway Garage							
5	034	1/29/15	11:55	X		Rt. 22 21953 True Value							
6		1/29/15	11:55	X		Rt. 22 21953 True Value							
7		1/29/15	11:55	X		Rt. 22 21953 True Value							
8	(1) 035	1/29/15	12:25		X	Raw Water - Stewart North	3 Separate samples w/ Separate ID's per note						
9	(2) 036	1/29/15	12:25		X	Raw Water - Stewart North							
10	(3) 037	1/29/15	12:25		X	Raw Water - Stewart North	SS 1-30-15						
11													
12													
13													
14													

RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED BY:(Signature)	DATE	TIME
[signature]	1/29/15	1245 PM			AM PM
		AM PM			AM PM
RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED FOR LABORATORY BY:	DATE	TIME
		AM PM	K Dumas	1-30-15	0945 AM

00 per logbook RP 2.11.15

LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT

LAB COMMENTS

CONDITIONS UPON RECEIPT (check one): + Iced: Wet/Blue ____ Ambient ____ 4 °C Upon Receipt____ N/A

MATRIX CODES:

DW-DRINKING WATER
RW-REAGENT WATER
GW-GROUND WATER
EW-EXPOSURE WATER
SW-SURFACE WATER
PW-POOL WATER
WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES

SW = Standard Written: (15 working days)	0%	IV* = Immediate Verbal: (3 working days)	100%
RV* = Rush Verbal: (5 working days)	50%	IW* =Immediate Written: (3 working days)	125%
RW* = Rush Written: (5 working days)	75%	SP* = Weekend, Holiday	CALL
		STAT* = Less than 48 hours	CALL

* Please call, expedited service not available for all testing

Samples received unannounced with less than 48 hours holding time remaining may be subject to additional charges.

06-LO-F0435 Issue 4.0 Effective Date: 2014-05-01

Sample analysis will be provided according to the standard EEA/Water Services Terms, which are available upon request. Any other terms proposed by Customer are deemed material alterations and are rejected unless expressly agree to in writing by EEA.

eurofins | Eaton Analytical

110 S. Hill Street
South Bend, IN 46617
T: 1.800.332.4345
F: 1.574.233.8207

Order # _____

Batch # _____

www.eatonanalytical.com

Shaded area for EEA use only

CHAIN OF CUSTODY RECORD

Page _____ of _____

REPORT TO:	SAMPLER (Signature)	PWS ID #	STATE (sample origin)	PROJECT NAME	PO#

BILL TO: Hooside FALLS
24 MAIN ST. Hooside FALLS N Y

COMPLIANCE MONITORING	Yes	No	POPULATION SERVED	SOURCE WATER

LAB Number	COLLECTION DATE	COLLECTION TIME	AM	PM	SAMPLING SITE	TEST NAME	SAMPLE REMARKS	CHLORINATED YES	CHLORINATED NO	# OF CONTAINERS	MATRIX CODE	TURNAROUND TIME
1 3179,038	1-30-15				4	Preserved Spike						
2 039					5							
3 040					6							
4 041					7							
5 042					8	Unpreserved Spike						
6												
7 043					LTB		A					
8 044												
9 1-30-15												
10												
11												
12												
13												
14												

RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED BY:(Signature)	DATE	TIME
	1/30/15	1230 AM (PM)			AM PM
RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED BY:(Signature)	DATE	TIME
		AM PM			AM PM
RELINQUISHED BY:(Signature)	DATE	TIME	RECEIVED FOR LABORATORY BY:	DATE	TIME
		AM PM	K Dyno	1-30-15	0945 AM PM

LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT

LAB COMMENTS
Samples were not checked for free Chlorine per client. KD

00 per logbook RP 2.11.15
CONDITIONS UPON RECEIPT (check one): 4
X Iced: Wet/Blue ____ Ambient ____ °C Upon Receipt____ N/A

MATRIX CODES:

DW-DRINKING WATER
RW-REAGENT WATER
GW-GROUND WATER
EW-EXPOSURE WATER
SW-SURFACE WATER
PW-POOL WATER
WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES

SW = Standard Written: (15 working days)	0%	IV* = Immediate Verbal: (3 working days)	100%
RV* = Rush Verbal: (5 working days)	50%	IW* =Immediate Written: (3 working days)	125%
RW* = Rush Written: (5 working days)	75%	SP* = Weekend, Holiday	CALL
		STAT* = Less than 48 hours	CALL

* Please call, expedited service not available for all testing

Samples received unannounced with less than 48 hours holding time remaining may be subject to additional charges.